



thermoscreens®

PHVR RECESSED HEAT PUMP RANGE AIR CURTAINS INSTALLATION, OPERATION & MAINTENANCE INSTRUCTIONS



For use with Mr Slim units

PLEASE READ THESE INSTRUCTIONS CAREFULLY BEFORE ATTEMPTING INSTALLATION




Thermoscreens Ltd
St. Mary's Road Nuneaton
Warwickshire England
CV11 5AU

Email: sales@thermoscreens.com
Tel: +44 (0) 24 7638 4646
Fax: +44 (0) 24 7638 8578
www.thermoscreens.com

English

Thermoscreens / Mitsubishi Electric

Heat Pump Warm Air Curtain System



The Heat Pump Warm Air Curtain System consists of :-

- a Thermoscreens 'PHVR Air Curtain' fitted with a PAC-IF010 Mitsubishi Electric Interface PCB
- a Mitsubishi Electric 'Mr Slim Outdoor Unit'
- a Thermoscreens 'Manual Room Control' for the manual control option by the occupant

Refer to Mitsubishi Electric if the air curtain is to be controlled via a Building Management System (BMS) or Centralised Controller. Do not install Manual Room Control and BMS/Centralised Control components together, install either one or the other.

A communications link is supplied to the Thermoscreens Heat Pump Air Curtain from the Mitsubishi Electric Outdoor Unit. This link provides control of the heat output of the air curtain and tells the air curtain when the outdoor unit is in defrost mode so auxiliary electric element heaters (if specified) can provide partial heat back-up during the few minutes of defrost.


The Air Curtain requires a permanent 3 phase electrical supply (3L+N+E) from a local switched spur to provide power to the defrost cycle electric heating elements, the air curtain fans and the Mitsubishi Electric Interface PCB. If the defrost cycle electric elements are not required they can be permanently disconnected, see 'Electrical Connections', and a 1 phase electrical supply (1L+N+E) used instead.

High and Low Output in this document refers to the heat pump heating capacity of the Air Curtain, not to any electrical rating.


UNPACKING THE PHVR HEAT PUMP AIR CURTAIN

The following items are supplied and packaged within the air curtain box.

PHVR Recessed Heat Pump Air Curtain




Manual Room Control



The Recessed Grille is packed in a separate box but comes with the air curtain:-

Recessed Grille with Filter



If anything is missing or damaged please contact your place of purchase immediately

There will also be a “Mr Slim Outdoor Unit” supplied by Mitsubishi Electric.

The complete Thermoscreens/Mitsubishi Electric heat pump system, to provide a heat pump warm air curtain over a doorway, including wiring, fridge pipework, etc. is to be installed only by an approved Mitsubishi Electric refrigeration contractor.

For your records

Date of Purchase.....
Place of Purchase.....
Serial Number.....

For warranty purposes proof of purchase is necessary so please keep a copy of your invoice.

IMPORTANT

This Heat Pump Air Curtain is intended only for use with a Mitsubishi Electric Mr Slim Outdoor Unit, for use on R410a with a condensing temperature of 49°C.

These instructions must be read in conjunction with the Mitsubishi Electric Mr Slim Outdoor Unit instructions.


(All documentation supplied with each unit should be stored and kept for future reference.)

INSTALLATION OF THE HEAT PUMP AIR CURTAIN

The air curtain is designed to be recessed within ceiling voids or bulkheads within a building and located horizontally over a doorway. It must not be installed outside of the building. The air curtain is intended for use as a heating only unit.

■ Location

The air curtain must be mounted so the recessed grille is between 1.8m minimum and 3.5m maximum above floor level and situated as close to the doorway as possible. The air discharge section of the recessed grille must be nearest to the doorway and the Air Inlet section furthest from the doorway. Beware of doorway top edges, structural beams, door opening/closure devices, etc. which may interfere with the air stream and affect the location of the unit.




Ensure there will be adequate clear space above the top of the unit within the ceiling void to safely allow for pipework brazing operations.

The PHVR Recessed Heat Pump air curtain has a rectangular air ventilation hole with Void Filter on one side of the unit, see photo of unit on Page 3. This air ventilation hole will be inside the ceiling void once the air curtain is installed and air from the void needs to enter it for the correct operation of the unit. There must be a clearance gap of 80mm minimum between this ventilation hole and any obstruction/bulkhead within the ceiling void to allow ventilation air from the void to easily enter the air curtain. Furthermore, the ceiling void must be sufficiently large and freely ventilated so there will be an adequate supply of ventilation air (m^3/hr) to the unit (see table below). If the ceiling void is enclosed around the air curtain it will need an air ventilation grille of effective free area (cm^2) as given in the table below and an adequate air path within the void for air to enter the rectangular air ventilation hole.

Air Curtain	Required air flow within ceiling void (m^3/hr)	Effective free area of ventilation grille for an enclosed ceiling void (cm^2)
PHV1000R DXE HO	353	500
PHV1500R DXE LO	421	700
PHV1500R DXE HO	421	700
PHV2000R DXE LO	707	1200
PHV2000R DXE HO	707	1200

■ Ceiling Suspension

Make the cut-out in the ceiling to the dimensions given in Figure 1, overleaf being as accurate as possible. The air curtain can be manoeuvred straight up through the ceiling cut-out. Alternatively the ceiling can be fitted after the air curtain is installed. Bear in mind it will be necessary to carry out pipework brazing operations above the air curtain once it is located in position. Ensure there is sufficient height clearance within the ceiling void to do this.



Holes are provided in the top face of the casing (see Figure 1 for positions) to allow the unit to be suspended on M10 threaded rods (not provided). All suspension points must be used.

Air Curtain	Weight (kg)	Number of hanging points
PHV1000R DXE HO	45	4
PHV1500R DXE LO	66	6
PHV1500R DXE HO	67	6
PHV2000R DXE LO	85	6
PHV2000R DXE HO	88	6




Four of the threaded rods (the two at each end of the unit) enter the casing from above and are attached to fixing brackets near the bottom of the unit (see photo above – looking up into the air curtain). The two centre threaded rods (on PHV1500 and PHV2000 units) are attached to the top face of the casing.

Ensure each of the threaded rods is secured onto a suitable structure that can support the weight of the unit (see table above)*. When fitting the threaded rod ensure that it does not interfere with internal components. Threaded rod should engage into fixing holes by a minimum of 20mm and locking nuts fitted to prevent the rod rotating and coming away from its fixing point.

Note: When installing the air curtain ensure that the underside of the casing is between 40mm and 65mm above the exposed bottom face of the ceiling tile/plasterboard (see Figure 1). The recessed grille and other air curtain components have adjustment within this range, although aim to achieve the minimum 40mm if possible.

*It is the sole responsibility of the installer to ensure that the building fixing points and suspension system used are suitable for the air curtain being installed.




		PHV1000R DXE	PHV1500R DXE	PHV2000R DXE
Cut-Out in Ceiling	A(mm)	1150	1650	2240
	B(mm)	N/A	800	1095
	C(mm)	1190	1690	2290
Length(mm)	Length(mm)	1155	1655	2245
	Width(mm)	445	445	445

FIGURE 1 – DIMENSIONS OF PHVR RECESSED HEAT PUMP AIR CURTAIN

■ Fitting the Recessed Grille

The recessed grille consists of a frame and grille core with filter attached to it.

Fix the four fixing brackets to the grille frame using an M4 screw to fit each fixing bracket. Note which fixing brackets go where (see photo), there are two shapes.



Remove the grille core from the grille frame by unfastening the two conical bolts fitted at each end of the grille core using an 8mm spanner.



Then push the grille core sideways against the spring loaded pins on one side and the grille core with filter now comes clear of its frame.

Note: The grille core with filter attached will still be tethered to the frame via safety cords and will hang down on these cords.



Locate the four M6 bolts that will hold the grille fixing brackets to the air curtain (two inside each end of the unit) and remove these M6 bolts. Lift the frame into position so the air discharge section of the grille will align with the air discharge vanes from the air curtain (see Figure 1 and photos on Page 3). Screw an M6 bolt through the slot in each grille fixing bracket until all four are located in place. Adjust the height of the grille frame (via the slots in the fixing brackets) so the frame fits neatly against the cut-out in the ceiling. Tighten each M6 bolt in place locking the grille frame in the correct position up against the underside of the finished ceiling.

The grille core will now be hanging down on its safety cords exposing all the components up inside the air curtain. Within the air curtain there are sliding air separator plates, two on the PHV2000 and one on the PHV1500 and PHV1000. These need to be adjusted up or down to stop the discharge air re-circulating back into the air curtain. Release the M6 bolts at each end of the plate, extend the sliding plate down so it will just touch the topside of the grille along its whole length when the grille core is fitted and tighten the bolts (see photo and Figure 1). It is necessary to temporarily fit the grille core to gauge the required height of the air separator plate(s).



Re-fit the grille core by locating each spring loaded pin in its locating hole, push against the spring loaded pins so the fixed pins at the other side of the grille core locate in their fixing holes in the frame. Tighten and secure the conical bolts fitted at each end of the grille core to lock it in position.

Note: Access for electrical connections and all servicing is by removing the grille core.

Once work on the ceiling is finished remove the protective plastic film from the recessed grille frame.

■ Mitsubishi Electric Outdoor Unit

The Mitsubishi Electric Outdoor Unit is selected to match its refrigerant heat output to the size of the Air Curtain. See table below for size of outdoor unit to be used together with performance data for the air curtain.

Air Curtain	Mr Slim Outdoor Unit	Heat Output (kW) @outdoor air 7/6°C db/wb		Max. Air Volume Flow Rate (m³/h)	Max. Noise Level dB(A) @3m
		Full Heat	Half Heat		
PHV1000R DXE HO	PUHZ-RP71VHA	8.6	5.34	1400	56
PHV1500R DXE LO	PUHZ-RP71VHA	10.1	5.6	2500	58
PHV1500R DXE HO	PUHZ-RP140VKA/YKA	14.4	8.3	2600	58
PHV2000R DXE LO	PUHZ-RP100VKA/YKA	14.1	7.9	3300	59
PHV2000R DXE HO	PUHZ-RP200YKA	21.3	11.2	3130	59

Indoor Air Temperature = 20°C

Performance figures derived from independent testing by UK test houses BRE and BSRIA in accordance with test standard EN 14511.

The air curtain normally operates under automatic temperature control and can also run at part load.

■ Refrigerant Pipework

This must be carried out before connection of any electrical and controls cables and in accordance with the Instructions that come with the Mitsubishi Electric Outdoor Unit. This work must only be undertaken by a Mitsubishi Electric approved Contractor.

Refrigerant installation pipework sizes are as follows :-

Air Curtain	Discharge Line (Gas)	Liquid Line	Maximum Pipe Run	
			Length	Height
PHV1000R DXE HO	5/8 in.	3/8 in.	50m	30m
PHV1500R DXE LO	5/8 in.	3/8 in.	50m	30m
PHV1500R DXE HO	5/8 in.	3/8 in.	50m	30m
PHV2000R DXE LO	5/8 in.	3/8 in.	50m	30m
PHV2000R DXE HO	1 1/8 in.	3/8 in.	100m	30m


It is intended that refrigerant pipe connections to the air curtain are made using brazed joints and these must be carried out in a professional and safe manner. If installation pipe sizes for the discharge (gas) line and liquid line are different from the pipe connection sizes on the air curtain, suitable pipe reducers must be used for the connection. R410a refrigerant systems can operate at pressures up to 610 psi (c. 42 Bar). These brazed joints may well be located in a public area and a weakness leading to an explosion could be extremely dangerous. The air curtain with its coil is

manufactured in accordance with the Pressure Equipment Directive and the installation must be carried out to a good standard of workmanship. Use a heat sink on the copper pipes when brazing to reduce the transfer of heat to the inside of the air curtain where sensitive components are located.

■ To gain access inside the Air Curtain

To gain access for connection of the electrical supply, controls wiring and to work on the unit during commissioning it is necessary to remove the grille core of the recessed grille.

Remove the grille core from the grille frame by unfastening the two conical bolts fitted at each end of the grille core using an 8mm spanner.



Then push the grille core sideways against the spring loaded pins on one side and the grille core with filter now comes clear of its frame.

Note: The grille core with filter attached will still be tethered to the frame via safety cords and will hang down on these cords.



■ Electrical Supply to the Air Curtain

This must be carried out AFTER the connection of the refrigerant pipework. All electrical wiring and connections MUST be carried out by a competent qualified electrician in accordance with the latest edition of the IEE wiring regulations and/or local statutory regulations. (see also Wiring Diagram on Page 12)

- A local isolator having a contact separation of at least 3mm on all poles must be fitted in the electrical supply to the air curtain and located in an accessible position adjacent to the unit. 1 phase if defrost electric heaters are not required. 3 phase if defrost electric heaters are required.
- The appliance must be connected using cables having an appropriate temperature rating (heat resistant).
- Ensure that the supply cables, circuit breakers and other electrical installation equipment are correctly sized for the air curtain being installed. See Table overleaf.
- A 20mm size cable gland or conduit connector should be used for the Electrical Supply into the air curtain.
- This appliance must be Earthed.

Air Curtain	230V/1ph/50Hz if defrost electric heaters are not used		400V/3ph/50Hz if defrost electric heaters are required	
	Rated Electrical Power Input (kW)	Rated Current (A)	Rated Electrical Power Input (kW)	Rated Current per phase (A)
PHV1000 DXE HO	0.3	1.3	4.8	7.8
PHV1500 DXE LO	0.35	1.8	7.8	12.7
PHV1500 DXE HO	0.35	1.8	7.8	12.7
PHV2000 DXE LO	0.5	2.7	9.5	15.7
PHV2000 DXE HO	0.5	2.7	9.5	15.7

If the defrost electric heaters are to be disabled this can be done by disconnecting the neutral wire (blue or purple) from terminal A2 on the contactor inside the air curtain. The disconnected wire should be terminated safely into unused auxiliary terminal 14NO as shown in the adjacent picture, or into a suitable terminal block (see also wiring diagram on Page 12).

Note: If the defrost electric heaters are disconnected, discharge air temperatures could be very cold, approximately 6°C. Defrost times could also be extended.



Wiring to the air curtain should be carried out in accordance with the wiring diagram on Page 12 and IEE Regulations. The figure below shows the completed wiring for a 3 phase electrical supply if the defrost electric heaters are required.

1) Connection from Mitsubishi Electric Outdoor Unit

Connections to terminals S2 and S3 provide a communications link between the Mitsubishi Electric Outdoor Unit and the Air Curtain. S1 in the Mitsubishi Electric Outdoor Unit is not used at all for this Air Curtain Indoor Unit.

2) Connecting a 400V/3ph/50Hz supply

Connect to terminals L1, L2, L3, N and E with a 3-phase electrical supply. This will power the electric heating elements during the defrost cycle, air curtain fans and the Mitsubishi Electric interface pcb.

Connecting a 230V/1ph/50Hz supply

Connect to terminals L1, N and E with a 1-phase electrical supply. This will power air curtain fans and Mitsubishi Electric interface pcb. **NB.** Electric heaters must be disabled !!



3) Connection from Manual Room Control (required only for manual control)

To comply with IEE regulations two separate 2-core, 230v mains rated double insulated cables of different colours should be used to wire from the manual room control. One 2-core cable is wired to terminals 1 & 2 (Heat Setting - signal voltage). The other 2-core cable is wired to terminals 3 & 4 (On/Off switch - 230v).

*If a BMS or Centralised Controller is to be used instead of Manual Control it is not necessary to wire to terminals 1-4. **NB.** Do not install Manual Room Control and BMS/Centralised Control together as they can interfere with each other.*

Recommended wire size for electrical connections are as follows:

1	2	3
1.0mm ²	2.5mm ² max for access	0.75mm ²

Do not use cable size of more than 2.5mm² or connecting the cable is difficult.

Electrical details for the Mitsubishi Electric Mr Slim Outdoor Unit are as follows:


Mr Slim Outdoor Unit	Electrical Supply (V/ph/Hz)	Rated Current per phase (A)	Mitsubishi recommended BS88 Fuse Size (A)
PUHZ-RP71VHA	230/1/50	19.0	20
PUHZ-RP100VHA	230/1/50	26.5	32
PUHZ-RP100YHA	415/3/50	8.0	10
PUHZ-RP140VHA	230/1/50	28.0	32
PUHZ-RP140YHA	415/3/50	11.0	16
PUHZ-RP200YHA	415/3/50	19.0	20

COMMISSIONING THE HEAT PUMP AIR CURTAIN

Ensure that the electrical supply to both the Mitsubishi Electric Outdoor Unit and the local electrical supply to the Air Curtain are switched off.

■ Air Curtain Checks

Check that the components inside the air curtain are as shown in the picture below. Check that the thermal overload cut-out switch has not 'tripped'. Push down on the red button on the top of the thermal overload switch - if it has tripped it will click back on.



Set the inner aluminium air vanes within the air curtain air discharge so they point straight downwards over the doorway.

NB. The Mr Slim Outdoor Unit can be test run using dip switch SW4-1 on the outdoor unit (air curtain also needs electrical power) do not run for more than 5 mins as it will operate in cooling.

A Mitsubishi Electric Interface PCB is located within the Thermoscreens Air Curtain to provide communication between the Mitsubishi Electric Outdoor Unit and the Air Curtain Indoor Unit.




The Interface PCB on its mounting plate is held in place by a screw located at the left-hand side of the board. Remove the fixing screw and carefully slide the pcb fully out.

The pcb on its mounting plate can hang freely below the unit.


For easier withdrawal of the pcb the connection to the filter indicator (shown as * in the right hand figure) may be temporarily removed.

Now go to either "BMS Control" or "Manual Room Control" to continue with the Commissioning of the Air Curtain.



■ BMS Control or Centralised Controller

On the Mitsubishi Electric Interface PCB check that the BMS Fan-Run Connection is plugged into position CNX1 (as shown on previous page and wiring diagram). The dip switches on the Interface PCB are factory set for BMS Control, check they are as follows:



Connect a computer running the appropriate software to the Mitsubishi Electric outdoor unit. Switch on electrical power to both the Mitsubishi Electric outdoor unit and the Air Curtain. **WARNING!** Interface PCB will have 230 volts on it. Communication between the Mitsubishi Electric Outdoor Unit and the Air Curtain commences approximately 30 seconds after power-up. After this time switch on the air curtain using the 'On Off Write' parameter of the BMS software.

Once the air curtain fans are operating check that they run at Low (I), Medium (II) and High (III) speeds using the manual 3 speed fan switch inside the left hand end of the air curtain. Check there is no excessive mechanical noise coming from the fans and that all fans are working. Select the fan speed appropriate to the site conditions and leave on this setting. LEDs 1, 2, 3 and 5 on the Interface PCB should be lit.

Set the BMS 'Mode' parameter to 2. Provided the return air temperature is below 28°C the air curtain should now be operating in heating mode. Check that the air stream from the discharge warms up across the whole length of the air curtain after approximately 20 minutes and that the air stream reaches right down across the doorway with the door open or closed. Set up the BMS schedule. It is possible to:

- switch the Air Curtain on and off
- determine whether the Air Curtain is operating
- monitor the Return Air Temperature
- monitor any Mitsubishi Electric system errors
- read/write the Mitsubishi Electric Outdoor Unit Mode (heating or ambient)

Note 1: The 'Mode' parameter should only be set to '2' (heating) or '6' (Fan-Ambient). The system is designed for heating or Fan-Ambient only, using other 'Mode' settings will result in incorrect operation or malfunction. **Never set the 'Mode' parameter to '1' (cooling)** as the air curtain is not designed to cope with condensate.

Note 2: The **set point and fan speed of the air curtain cannot be altered** through the BMS or Centralised Controller. The set point is hard coded to 28°C * via dip switch SW2 on the Mitsubishi Interface PCB in the air curtain. The fan speed is set manually at commissioning using the 3 speed fan switch inside the air curtain (see above).

* for Set Point 26°C use dip switch settings SW2-3 ON, SW2-4 OFF, SW2-5 ON


* for Set Point 24°C use dip switch settings SW2-3 OFF, SW2-4 OFF, SW2-5 ON

Switch off the electrical power to the Mitsubishi Electric Outdoor Unit and Air Curtain. Carefully slide the Interface PCB back into place, replacing the Filter Indication connection if removed earlier. Ensure cables are not trapped inside and refit retaining screw. The Filter Indicator Schedule can now be changed from its default setting if


required (see page 17). Refit the recessed grille core with air filter (see “To gain access inside the Air Curtain” page 9). Power-up both the Mitsubishi Electric Outdoor Unit and Air Curtain and re-check the operation of the unit.

■ Manual Room Control

On the Mitsubishi Electric Interface PCB the BMS Fan-Run Connection should be 'parked' at position CNX5 (green), see Wiring Diagram – Page 12. The dip switch settings should be as follows:



On the Thermoscreens Manual Room Control set the Fan On/Off switch to Off '0' and the Ambient/Heat switch to Ambient '⊗' Fan only. Switch on the electrical power to the Mitsubishi Electric outdoor unit and the Air Curtain. **WARNING!** Interface PCB will have 230 volts on it.



Communication between the Mitsubishi Electric Outdoor Unit and the Air Curtain commences approximately 30 seconds after power-up. After this time use the Room Control to switch on the fans. Once the air curtain fans are operating check that they run at Low (I), Medium (II) and High (III) speeds using the manual 3 speed fan switch inside the left hand end of the air curtain. Check there is no mechanical noise coming from the fans and that all fans are working. Select the fan speed appropriate to the site conditions and leave on this setting.

Using the Manual Room Control set the Ambient/Heat switch to Heat '〰️' and the heat setting switch to Full Heat '〰️'. Check that the air stream from the discharge warms up across the whole length of the air curtain after approximately 20 minutes and that the air stream reaches right down across the doorway with the door open or closed.

Use the Manual Room Control to test the different heat settings. LEDs 1-5 on the Interface PCB should be lit as follows.

- LED 1 indicates that there is power to the air curtain
- LEDS 2-5 indicate the different heating settings selected via the Manual Room Control heat setting switch

Heat setting	LEDs lit
ambient	1
half heat	1,3
full heat	1,3,5
automatic	1,2,3,5

Note 1: The **set point and fan speed of the air curtain cannot be altered** through the Manual Room Control. The set point is hard coded to 28°C * via dip switch SW2 on the Mitsubishi Interface PCB in the air curtain. The fan speed is set manually at commissioning using the 3 speed fan switch inside the air curtain, as described above.

* for Set Point 26°C use dip switch settings SW2-3 ON, SW2-4 OFF, SW2-5 ON

* for Set Point 24°C use dip switch settings SW2-3 OFF, SW2-4 OFF, SW2-5 ON

Switch off the electrical power to the Mitsubishi Electric Outdoor Unit and Air Curtain. Carefully slide the Interface PCB back into place, replacing the Filter Indication connection if removed earlier. Ensure cables are not trapped inside and refit retaining screw. The Filter Indicator Schedule can now be changed from its default setting if required (see page 17). Refit the recessed grille core with air filter (see “To gain access inside the Air Curtain” page 9). Power-up both the Mitsubishi Electric Outdoor Unit and Air Curtain and re-check the operation of the unit via the Manual Room Control.

■ Filter Dirty Indicator


The air curtain is fitted with a Filter Dirty Indicator. It is located at the left-hand end of the air discharge grille and signals when the air curtain inlet grille filters should be vacuum cleaned or the air curtain requires servicing.



The indicator states are outlined below:




Indicator State	Indicator Light	Action Required	Reset Button
GREEN FLASH	On 0.5s; Off 3s	None	N/A
RED ON	On permanently	Vacuum inlet	Quick reset
RED FLASH	On 0.5s; Off 0.5s	Service filters	Press for 5s

The filter indicator schedule is based on fan operating hours. For the default schedule, shown schematically below, the inlet grille filter should be vacuum cleaned every 120hrs of fan operation (every 1 to 2 weeks) and a full service should take place every 480hrs of fan operation.



The factory set default schedule is suitable for most applications. However, the actual frequency of cleaning required will depend on the environment. Two alternative filter

indicator schedules are available, and can be selected by changing the 'jumper' position (marked 1, 2 or 3) on the Filter Indicator pcb.

Filter Indicator Schedule	Double-frequency	Default	Half-frequency
Jumper position	 1 2 3	 1 2 3	 1 2 3
Inlet grille vacuum interval	60 hrs	120 hrs	240 hrs
Filter service interval	240 hrs	480 hrs	960 hrs


To access the Filter Indicator pcb to change jumper position :-

Switch off the electrical power to the Heat Pump Air Curtain. Remove the recessed grille core from the air curtain (see To gain access inside the Air Curtain, Page 9). Unfasten the two screws as indicated.



The Filter Indicator pcb is now accessible to change the jumper position.

Once the filter indicator pcb 'jumper' has been re-positioned, re-fit the filter indicator and replace the recessed grille core.



+ Hand-over to End-User

Before leaving site it is important that there is a 'Hand-Over Meeting' to hand-over the heat pump system and air curtain installation to the end user or their representative. This should include a full and clear explanation of how the system operates and a demonstration showing the air curtain running. Be sure to explain the Filter Indicator Schedule, that the air inlet grille must be regularly vacuum cleaned and the unit serviced at regular intervals.

If the air curtain is to be operated under manual control, it is important that the end user understands how the Thermoscreens Manual Room Control operates (see Page 15). That the air curtain operates in FAN (Ambient) mode or in HEAT mode with a fixed target temperature of 28°C, or less if the hard coded set point has been changed via dip switch SW2 on the Mitsubishi Interface PCB in the air curtain (see Page 14).

If the air curtain is to be operated under the control of a BMS System or Centralised Controller, explain all the settings and demonstrate the operation of the system. That the air curtain should be operated in FAN (Ambient) mode or in HEAT mode with a fixed target temperature of 28°C, or less if the hard coded set point has been changed via dip

switch SW2 on the Mitsubishi Interface PCB in the air curtain (see Page 14). It is vital they understand that the air curtain must not be run in COOL or AUTO mode.

Ensure that all instructions and manuals are handed to the end user or their representative.

SERVICING THE HEAT PUMP AIR CURTAIN

■ Vacuum Clean the Air Inlet Grilles / Filters

(Weekly, or when the Filter Dirty Indicator shows **PERMANENT RED**)

With the air curtain switched OFF, a vacuum cleaner with an extension tube and brush attachment at its end should be used to clean the face of the air inlet grille and the filter at the back of the grille. This is important to minimise the build-up of dust and lint on the air filter which will affect the performance of the air curtain. This is a simple service task that can be carried out by the Cleaner or Janitor on a weekly basis from floor level without having to access the air curtain at high level. This should be done weekly as a regular service task and/or when the Filter Dirty Indicator shows permanent red.



Reset the Filter Dirty Indicator after cleaning by a quick press of the Reset Button (even if the indicator has not gone red).

■ Servicing the Air Curtain

(suggest every 3 Months, or if the Filter Dirty Indicator shows **FLASHING RED**)

Always disconnect and isolate the mains electricity supply both at the local electrical supply to the Air Curtain and at the Mitsubishi Electric Outdoor Unit before servicing, maintaining or repairing the Air Curtain.

Note: All servicing, maintenance and repairs to the air curtain must be carried out by an approved Service Agent.




Towards the rear of the recessed grille (nearest the doorway), and at each end of the grille, there are two conical bolts that prevent the grille being removed without the use of tools.

Loosen these two conical bolts using an 8mm spanner.

Then push the grille core towards the doorway against spring loaded pins on one side and the grille core with filter now comes clear of its frame.



Note: The grille core with filter attached will still be tethered to the frame via safety cords and will hang down on these cords.





The grille filter can now be unclipped from the grille and brushed and vacuum cleaned.

Looking up inside at the front edge of the unit (the edge furthest from the doorway) there are 2 or 3 screws inset into the frame (see photo). Loosen each of these screws by 2 turns.



Reach up and pull the metal retaining strip over to one side and remove the retaining strip.

Pull the void filter outwards at the bottom and then remove from the air curtain. It can then be brushed and vacuum cleaned.



Refit the filters opposite to removal. The filters are very durable but may need to be replaced after a number of service intervals.

Vacuum clean and remove any build-up of dust, dirt and debris within the air-curtain, especially on the face of the coil and the electric heating elements.

Note: Fan motors are permanently lubricated and require no additional lubrication.

Once the air curtain has been cleaned, visually inspect the air curtain components. Ensure pipe temperature sensors are located in their pockets and any foam insulation covering these pockets is un-damaged. Check the location of the thermal overhear cut-out and air sensor and that the thermal overhear cut-out switch has not tripped (see Section – Commissioning, Page 13). Check all electrical connections and terminals within the unit are tight and that crimp connections have not become loose.

After all the components have been re-fitted switch on the electrical supplies and fully function test the air curtain to ensure correct operation (see Section – Commissioning, Page 13).

Reset the Filter Dirty Indicator after the service by pressing the Reset Button for at least 5 seconds (even if the indicator has not gone flashing red).and hand back the unit to the end user.



■ Fault Conditions

If the Thermoscreens Heat Pump Warm Air Curtain System does not operate as expected refer to the fault finding table below:

Symptom	Possible Cause	Action Required
Air curtain does not operate	Electrical power is not switched on at both the Mitsubishi Electric Outdoor Unit <u>and</u> at the local electrical isolator next to the Thermoscreens Air Curtain	Switch on power to Mitsubishi Electric Outdoor Unit <u>and</u> Thermoscreens Air Curtain and wait for 30 seconds
	BMS Control: Air curtain is set to 'Off'.	Check BMS schedule and amend if necessary
	Manual Control: Manual Room Control, Fan On/Off switch set to Off '0'	Use Manual Room Control to adjust fan and heat settings as appropriate
	Problem with air curtain fan motor(s), or internal wiring, or controls	Use wiring diagram to investigate possible cause of fault
Air curtain is discharging cold air	Air curtain has been running for less than 20 minutes and is still warming up	Give system sufficient time to reach operating condition
	BMS Control: Air curtain is set to FAN (Ambient)	Check BMS schedule and change to HEAT if necessary
	Manual Control: Manual Room Control, Ambient/Heat switch is set to FAN (Ambient) '✕'	Use Room Control to adjust fan and heat settings as appropriate
	Fixed Target Temperature on dip switch SW2 on Mitsubishi interface pcb in air curtain is set too low for heating	If necessary adjust the fixed target temperature via dip switch SW2 (see Page 14)
	Manual Control: Heat setting switch on Manual Room Control is set to 'AUTO' and the SW2 fixed target temperature has been exceeded	NB. Air Curtain will only heat if room air temperature is below the target temperature.
	Air Curtain filters and/or heating coil is dirty.	Service air curtain as described in Section – Servicing on pages 19 & 20
Mitsubishi Electric system is indicating an error code	A variety of error codes can occur because of a fault within the air curtain	Refer to Mitsubishi Electric Service Manual to understand fault, then inspect and repair air curtain if there is a fault

If the Heat Pump Warm Air Curtain System is still not operating correctly call for a Mitsubishi Electric Service Agent.

■ Warranty

If any problems are encountered with the heat pump warm air curtain please contact your Mitsubishi Electric Service Agent.

Care has been taken in compiling these instructions to ensure they are correct, although Thermoscreens Ltd. disclaims all liability for damage resulting from any inaccuracies and/or deficiencies in this documentation. Thermoscreens Ltd. retain the right to change the specifications stated in these instructions.

Thermoscreens Ltd
St. Mary's Road Nuneaton
Warwickshire England
CV11 5AU

Email: sales@thermoscreens.com

Tel: + 44 (0) 24 7638 4646

Fax: + 44 (0) 24 7638 8578

www.thermoscreens.com

Thermoscreens Ltd
St. Mary's Road
Nuneaton
Warwickshire
CV11 5AU
United Kingdom
Telephone: +44 (0)24 7638 4646
Fax: +44 (0)24 7638 8578



EC DECLARATION OF CONFORMITY

as defined by the EC Council Directive on Machinery 2006/42/EC, the Low Voltage Directive 73/23/EEC, the Electromagnetic Compatibility Directive 89/336/EEC and the Pressure Equipment Directive 97/23/EC

Herewith we declare that the air movement equipment designated below, on the basis of its design and construction in the form brought onto the market by us in accordance with the relevant safety, health and performance requirements of the Machinery.

If alterations are made to the machinery without prior written permission from us this declaration becomes invalid.

Designation of Equipment :	THERMOSCREENS AIR CURTAINS
Series Type :	PHV1000 DXE HO, PHV1000RDXE HO, PHV1500 DXE LO, PHV1500RDXE LO, PHV1500 DXE HO, PHV1500R DXE HO, PHV2000 DXE LO, PHV2000R DXE LO, PHV2000 DXE HO, PHV2000R DXE HO
Relevant EC Council	the Machinery Directive (2006/42/EC) the Low Voltage Directive (73/23/EEC as amended by 93/68/EEC) the Electromagnetic Compatibility Directive (89/336/EEC as amended by 91/31/EEC and 93/68/EEC) the Pressure Equipment Directive (97/23/EC)
Applied Harmonised Standards :	Machinery - EN 292-1, EN 292-2, EN 294, EN 394, EN 414 LVD - EN 60335-1, EN 60335-2-30, EN 60335-2-40 EMC - EN55011, EN 61000-3-2, EN 61000-3-3, EN 61000-4-2, EN 61000-4-4, EN61000-4-5, EN61000-4-11, EN61000-6-4 PED - EN 13134, EN 13133
Basis of Self Attestation :	Quality Assurance to BS EN ISO 9001 : 2000 B.S.I. Registered Firm Certificate Number FM 85224
Responsible Person :	Mr. M. Francis, Managing Director, Thermoscreens Limited
Date :	17 th June 2009

Signed :